

**CITY OF FERNDALE
REQUEST FOR COUNCIL ACTION**

FROM: Byron A. Photiades, DPW Director

SUBJECT: Approval of Bill for Fuel Tank Repair

SUMMARY & BACKGROUND:

The unleaded-fuel tank at the city yard had to be repaired because of water penetrating the tank. Initially, having only one week's fuel supply left for DPW and emergency vehicles, we directed Rhodes Welding, of Ferndale, to repair the tank.

Rhodes repaired the tank continually over seven weeks. The expense amounted to \$10,533; it would be charged to the Vehicle and Equipment Fund, Repair and Maintenance, account # 661-000-775.

Attachments: DPW Superintendent Memo
Rhodes Welding Bill

COUNCIL AGENDA DATE: August 11, 2008

CITY ATTORNEY REVIEW: N/A

FINANCE DIRECTOR REVIEW: JCHubanks, 8/4/08

CITY MANAGER APPROVAL: Robert J. Bruner, Jr.

COMMENTS:


RECOMMENDED ACTION:

Moved by , seconded by , to approve the bill of \$10,533 of Rhodes Welding, of Ferndale, for repairing the unleaded-fuel tank at the city yard, and to charge the expense to the Vehicle and Equipment Fund, Repair and Maintenance, account number 661-775.

CITY OF FERNDALE

INTER-OFFICE CORRESPONDENCE

TO: Byron Photiades
DPW Director


FROM: Jack Crowley
DPW Superintendent

SUBJECT: Emergency Repair –
Fuel Tank

DATE: August 1, 2008

Our gasoline supplier is shipping a new blend of gasoline that has more ethanol, which will separate if there is any water in our fuel tanks. The previous fuel product was unaffected by this and would just allow water to settle to the bottom of the tank.

As there was water in the unleaded fuel tank, our supplier would not deliver unleaded fuel to us. In order to take delivery (we only had about a one-week supply left), Rhodes Welding was called in and repaired the fill and vent tube and also replaced two probes.

JWC/rs

Rhodes Welding Co., Inc.

750 Meadowdale St.

Ferndale, MI 48220

REC'D JUL 30 2008

Telephone: 248 543-0212

Fax: 248 398-8463

Office Telephone: 248 398-5464

TO:
City of Ferndale
300 E. Nine Mile Rd.

7/15/2008 INVOICE 03,196

Ferndale Mi. 48220

ProductID	Description	Qty	Price	Ext'd
05,924-	EBW AUTO LIMITER	1.00	\$830.78	\$830.78
05,931-	PIPE 4 S/40 304/L X 2' 0 0-1/2 TUBE	1.00	\$172.95	\$172.95
05,932-	PIPE 4 S/40 304L TUBE 0' - 8"	1.00	\$64.31	\$64.31
05,933-	JOMAR HW TEFLON - PT	1.00	\$35.36	\$35.36
05,948-	2 ORESSYRE VAC UUM VENT	1.00	\$177.53	\$177.53
05,949-	104-3200 SAR-GEL 1 OZ.	2.00	\$17.05	\$34.10
05,950-	12 MAN HOLE 104A-12000	1.00	\$134.28	\$134.28
05,943-	2 VENT VALVE ASSEMBLY	1.00	\$139.35	\$139.35
05,925-	TOP SEAL	1.00	\$55.36	\$55.36
05,927-	DEVR SPILL CONT	1.00	\$714.58	\$714.58
05,928-	BRASS ADAPTER	1.00	\$133.93	\$133.93
05,929-	VAPOR RECOVERY TUBE	1.00	\$161.11	\$161.11
05,930-	ORANGE FILLCAP	1.00	\$57.14	\$57.14
05,434-	STEEL PLATE 1/2" FOR VAPOR RECOVERY CON.LID	1.00	\$50.00	\$50.00
05,965-	VEEDER ROOT INNERSTENCIAL SPACE MONITOR	1.00	\$460.08	\$460.08
05,275-	LABOR - 2 MEN - SEE ATTACHED	56.25	\$130.00	\$7,312.50

Job Description:
REPAIRS TO UNDERGROUND NO LEAD GASOLINE STORAGE TANK.

661-775
BWP

WORK ORDER #	DATE OF SERVICE	PURCHASE ORDER	JOBSITE
VARIOUS	VARIOUS - SEE A		

Purchases:	\$10,533.36
Shipping:	\$0.00
State Tax:	\$0.00

Terms Net 30 Days, 1.5% service charge per month will be added after 30 days.

Grand Total: \$10,533.36

RHODES, INC.

750 MEADOWDALE, FERNDALÉ, MI. 48220

PHONE:(248)399-5464

FAX: (248) 398-8463

July 15, 2008

City of Ferndale

Underground Storage Repair

5/16/08	Fabricate lid for vapor recovery connection	2 hrs.
5/19/08	Inspect no lead tank and remove drop tube	7 hrs.
5/20/08	Start to install fuel fill pipe in tank	7.75
5/21/08	Finish fill	4.5
5/23/08	Install drop tube	4.
6/4/08	Work with H.Domini to verify underground tank leaks	3.25
6/9/08	Uncover and inspect fuel tank connections	9.
6/10/08	Install vent ass'y and vapor recovery	3.5
6/11/08	Monitor fuel and water levels. Install pressure vacuum vent	3
6/17/08	Remove interstitial space monitor probe	3.25
6/24/08	Finish installing new pressure vacuum vent controls	3
7/1/08	Change pipe for interstitial space monitor	3.
7/7/08	Inspect tank for proper operation	3
	Hours:	56.25

QUALITY SINCE 1951

TERMS: NET 30 DAYS. 1 1/2% SERVICE CHG. PER MONTH WILL BE ADDED AFTER 30 DAYS.